



# **Heath Department of Public Safety**

## ***Fire Department Connection (FDC) Sign***

### ***Design Requirements***

1. Located on Structure
  - a. Sign shall be constructed from an 18" high by 24" wide metal substrate no thinner than .063.
  - b. Sign shall have round corners.
  - c. Background color of sign shall be "fire engine red" non-reflective.
  - d. White reflective letters shall be used as set out below.
  - e. Letters shall be a font comparable to "folio medium" or Helvetica medium."
  - f. Sign shall be permanently attached to wall directly above the fire department connection. It shall be 72" above the ground to the bottom of sign, unless otherwise approved by Fire Marshal.
  - g. First line ("FDC") shall be 6" high letters with 3" between letters.
  - h. Second and third lines shall be 4" high letters with ½ inch spacing between letters.
  - i. There shall be a 1" margin completely around sign and 1" spacing between lines of text.
  - j. There shall be 2" spacing between any complete words.
2. Located remotely
  - a. Sign shall be constructed from an 12" high by 18" wide metal substrate no thinner than .063.
  - b. Sign shall have round corners.
  - c. Background color of sign shall be "fire engine red" non-reflective.
  - d. White reflective letters shall be used as set out below.
  - e. Letters shall be a font comparable to "folio medium" or Helvetica medium."
  - f. Sign shall be permanently attached to FDC at a midpoint from the connection and grade level, unless otherwise approved by Fire Marshal.
  - g. First line ("FDC") shall be 4" high letters with 3" between letters.
  - h. Second and third lines shall be 3" high letters with ½ inch spacing between letters.
  - i. There shall be a 1" margin completely around sign and 1" spacing between lines of text.
  - j. There shall be 2" spacing between any complete words.

